

Water Quality Data for WSWA System 45014

	MCLG or MRDLG	MCL, TT, MRDL or AL	WSWA Water	Sample Date	Violation or # of samples exceeding AL	Typical Source of Contaminant
Microbiological Contaminants						
Total Coliform Positive samples	0	0	0	2017 one/month	No	Present in the environment
Inorganic Contaminants						
Nitrate (ppm)	10	10	ND	8/10/2017	No	Runoff from fertilizer use; Leaching from septic tanks; Erosion from natural deposits NEXT DUE 8/2017
Lead - action level at consumer taps (ppm)	0	0.015	0.0037	12/23/2017	0	Corrosion of household plumbing systems; Erosion of natural deposits NEXT DUE JULY 2017
Copper-action level at consumer taps (ppm)	1.3	1.3	0.227	12/23/2017	0	Corrosion of household plumbing systems; Erosion of natural deposits. NEXT DUE JULY 2017
Radioactive Contaminants						
Radium 228 (pCi/L)	0	0	0.300	2017	No	Natural deposits
Gross Alpha (pCi/L)	0	15	.268	2017	No	Natural deposits

Violations and Exceedences

PAST DUE SAMPLING REQUIREMENT GROSS ALPH, RADIUM 228